

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Muster AG
Muster Str. 25, 12345 Musterstadt, Germany

the Certificate No: Z10101 for the PROFINET IO Device:

Model Name: Musterdevice
Revision: 1.0; SW/FW: 1.0 HW: 1.0
Identnumber: 0x0101; 0x1010
GSD: GSDML-V2.31-Muster-Musterdevice-20160230.xml
DAP: DAP, 0x01234567

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	PNIO_Version	V2.31
<input checked="" type="checkbox"/>	Conformance Class	C
	Optional Features:	Legacy, MRP, DeviceAccess
<input checked="" type="checkbox"/>	Netload Class	III
<input checked="" type="checkbox"/>	PNIO_Tester_Version	V2.3.5
<input checked="" type="checkbox"/>	Tester	Testlab AG, Germany PN-00-0

This certificate is granted according to the document:

"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by January 31, 2019 the certificate is valid for life.

Karlsruhe, February 19, 2016

Board of PROFIBUS Nutzerorganisation e.V.




(Official in Charge)

(1. Vorsitzender)



(2. Vorsitzender)

Eftersom specifikationen för **PROFINET** är öppen och standardiserad, kan vem som helst bygga och sälja produkter med PROFINET. För att garantera att användare får den kvalitet de förväntar sig, har PI obligatorisk certifiering för PROFINET-produkter.

Oberoende testlaboratorier, PITL, ackrediterade av PI, utför test, som ser till att enheterna följer standardens specifikationer och att de funkar i applikationer tillsammans med produkter från andra tillverkare.

När produkten har ett godkänt testprotokoll utfärdar PI certifikatet.

Certifiering av PROFINET-produkter är en garanti för hög kvalitet.

[Läs mer.](#)

[TILLBAKA till se.profibus.com](http://se.profibus.com)