

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Rotork

Rotork House, Brassmill Lane, BA1 3JQ Bath, United Kingdom

the Certificate No: **Z13809** for the PROFINET Device:

Model Name: Rotork Integrated Ethernet Actuator
Revision: SW/FW: 1.04; HW: 01
Identnumber: 0x0125; 0x0033
GSD: GSDML-V2.45-Rotork Controls Ltd-Rotork Ethernet Actuator-20241105.xml
DAP: DAP1, 0x80010000

This certificate confirms that the product has successfully passed the certification tests with the following scope:

| | |
|---|--|
| <input checked="" type="checkbox"/> PNIO_Version | V2.44 |
| <input checked="" type="checkbox"/> Conformance Class | B |
| <input checked="" type="checkbox"/> Optional Features | Legacy, MRP, System Redundancy |
| <input checked="" type="checkbox"/> Netload Class | III |
| <input checked="" type="checkbox"/> PNIO_Tester_Version | Version 2.44.1.2 |
| <input checked="" type="checkbox"/> Tester | PROCENEC, Wateringen, The Netherlands; PCN238-PND-01 plus Manufacturer Declaration |

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **March 25, 2027** the certificate is valid for life.

Karlsruhe, December 18, 2024



(Official in Charge)



Board of PROFIBUS Nutzerorganisation e. V.



(Xaver Schmidt)



(Frank Moritz)