

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Emerson Automation Solutions

6021 Innovation Blvd, 55379 Shakopee, MN, USA

the Certificate No: **Z01513** for the PROFIBUS Slave:

Model Name: Rosemount 3051 Pressure Transmitter
 Revision: 2.0; SW/FW: 3.0.0; HW: 5
 GSD: Rmt14444.GSD; File Version 5.0
 PA139700.GSD

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Set_Slave_Add
<input checked="" type="checkbox"/>	DP-V1	MS2, Prm_Block_Structure, I&M
<input checked="" type="checkbox"/>	Profiles	PROFIBUS PA 3.02
<input checked="" type="checkbox"/>	Physical Layer	MBP

Test Report Number: MCDL-2019-062-D
 Authorized Test Laboratory: ITEI, Beijing, CHINA

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFIBUS DP Slaves, Version 3.09 from September 2008" and
 "Test Specification for PA Devices, Profile 3.02; Version 5.0.4, February 2010".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS products".

For all products that are placed in circulation by **January 30, 2028** the certificate is valid for life.

Karlsruhe, January 03, 2025

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)




(Xaver Schmidt)



(Frank Moritz)