

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Hilscher
Gesellschaft für Systemautomation mbH
 Rheinstr. 15
 65795 Hattersheim, Germany

Reference Implementation

The tested controller is a reference implementation of a Technology Component. Any controller using this implementation still needs to be certified with their own VendorID and DeviceID.

the Certificate No: **Z11717** for the PROFINET IO Controller:

Model Name: CIFX RE/PNM
 Order_Number: 1250.100
 Identnumber: 0x011E; 0x0203
 Revision: SW/FW: V3.2.0; HW: 5

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	PNIO_Version	V2.33
<input checked="" type="checkbox"/>	Conformance Class	B Optional features: Legacy, FSU
<input type="checkbox"/>	Netload Class	III
<input checked="" type="checkbox"/>	PNIO_Tester_Version	V2.33.0
<input checked="" type="checkbox"/>	Tester	Siemens AG, Fürth , Germany, PNC61-1

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **January 27, 2020** the certificate is valid for life.

Karlsruhe, March, 09, 2017


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)

(K.-P. Lindner)