

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Phoenix Contact GmbH & Co. KG

Flachsmarktstr. 8-28, 32825 Blomberg, Germany

the Certificate No: **Z11869** for the PROFINET IO Device:

Model Name: FL SWITCH IRT 4TX
 Revision: SW/FW: V3.0.0; HW: 01
 Identnumber: 0x00B0; 0x0078
 GSD: GSDML-V2.32-PhoenixContact-FL-SWITCH-IRT-20170331.xml
 DAP: DAP 4: FL SWITCH IRT 4TX - FW 3.00; 0x00000300

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.32
<input checked="" type="checkbox"/> Conformance Class	C
<input checked="" type="checkbox"/> Optional Features	Legacy, MRP Client and Master, Device_Access
<input checked="" type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	V2.33.2 with annex spirta
<input checked="" type="checkbox"/> Tester	Phoenix Testlab GmbH, Blomberg, Germany, PNE162128E01

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **March 31, 2029** the certificate is valid for life.

Karlsruhe, April 10, 2026



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Xaver Schmidt)




(Frank Moritz)